

BERNARDS TOWNSHIP PUBLIC SCHOOLS

101 Peachtree Road
Basking Ridge, New Jersey 07920

David Harding
Director of Facilities

Phone: 908-204-2600
Fax: 908-766-7641
E-mail: dharding@bernardsboe.com

August 25, 2016

To Whom it May Concern:

The Bernards Township Board of Education has completed district wide testing for lead in drinking water in accordance with the NJ Department of Environmental Protection and the Department of Education regulations.

The safety threshold for action is 15 parts per billion (ppb). Across all district schools there are a total of 237 water fountains and kitchen outlets used for consumption. All 237 locations were tested, the vast majority of which came back with results well below the actionable level. Six (6) samples were slightly above the 15 ppb (parts per billion) threshold; all six (6) locations have been mitigated already.

The district is in process of conducting follow up sampling at the mitigated locations. The district will continue monitoring and testing in accordance with NJ Department of Environmental Protection and the Department of Education regulations.

Please refer to the following report to view specific results for all 237 locations that were tested. The results of the follow up testing for the mitigated locations will be posted with this report as soon as they are available.

Very truly yours,



David Harding
Director of Facilities



1090 Bristol Road
Mountainside, NJ 07092
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Bernard Township Schools
100 Peachtree Rd, 101 Peachtree Rd,
70 W. Oak St, 70 Quincy Rd
61 Church St, 111 Hansom Rd,
& 268 S. Finley Ave
Basking Ridge, New Jersey 07920

Performed For:

Bernards Township Board of Education
David Harding
101 Peachtree Rd
Basking Ridge, NJ 07920

Prepared By:

LEW Corporation
1090 Bristol Road
Mountainside, NJ 07092

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 6/22-24/16
8/3/2016

Project Number: 160596 & 160329

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	5

Appendices


Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Laboratory Data
Appendix E	Sampling Forms
Appendix F	Company and Risk Assessor Certifications

Contact Information

Agency

Client Contact:	David Harding
Client Name:	Bernards Township Board of Education
Street Address:	101 Peachtree Rd Basking Ridge, NJ 07920
Phone Number:	(908) 204-2600 ext106

Risk Assessor(s)

Site Assessor(s):	Raheen Holland
License:	NJDOH 013217
Signature:	
Date:	August 10, 2016
E-Mail:	Rholland@lewcorp.com

Firm

Organization:	LEW Corporation
Certification #:	NJDCA 00015 E
Street:	1090 Bristol Road
City, State & Zip:	Mountainside, New Jersey 07092
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Schneider Laboratories, Inc.
Street:	2512 West Cary Street
City, State & Zip:	Richmond, Virginia 23220
Phone Number:	804-353-6778

Introduction

LEW Corporation was contracted by Bernards Township Board of Education to test for the presence of lead in drinking water in two schools in the district.

Sampling Methodology

Several sampling methodologies exist for sampling lead in drinking water. The United States Environmental Protection Agency (EPA) established the Safe Drinking Water Act (SDWA) and Lead and Copper Rule (LCR). Both of these documents regulate lead in public drinking water systems, which are defined as systems for the provision to the public of water for human consumption through pipes or other constructed conveyances, if such system has at least fifteen service connections or regularly serves at least twenty-five individuals. Bernard Township Schools is not considered a public water system as defined by these regulations. Therefore, sample collection, delivery and analysis were conducted according to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006 and NJDEP's "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water." These guidance documents contain recommendations on how to address lead in school drinking water systems not covered under the SDWA or LCR. The EPA document lists 20ppb of lead as the action level whereas NJDEP lists an action level of 15ppb, which is also the action level for the SDWA. For the purposes of this sampling, the more stringent level of 15 ppb will be followed.

All samples were collected in 250mL plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than eighteen hours.

After receiving results from the first draw samples, a second draw sample was collected from those found to be in exceedance of the standard. Prior to collecting the second draw sample, the outlet was flushed for the recommended time for each outlet type. Faucets and fountains without an attached cooling unit/reservoir were flushed for thirty seconds. Fountains and water coolers with an attached cooling unit/reservoir were flushed for fifteen minutes.

All samples were analyzed by Schneider Laboratories, Inc., 2512 West Cary Street Richmond, VA 23220, a third party laboratory.

Drinking Water Results

June 22 – 24, 2016

LEW Corporation collected a total of 237 first draw samples from 237 drinking points. 6 samples from 237 drinking points tested above the 15ppb action level for first draw sample.

August 3, 2016

LEW Corporation returned to collect second draw samples from the 6 locations that exhibited concentrations above 15ppb during the initial sampling. Of the 6 second draw samples, none were above the 15ppb concentration but one sample collected had concentrations above 10ppb, where the EPA guidance document recommends treatment.

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix D.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
		None

Recommendations

For those outlets where the first draw sample exceeds 15ppb and the second draw sample is close to 5ppb, the outlet is contributing lead to the drinking water and very little lead is being picked up upstream of the outlet in the building plumbing. LEW Corporation recommends immediately stopping use of these outlets. LEW Corporation then recommends replacing the outlet and associated plumbing up to the wall connection.

For those outlets where the first draw sample exceeds 15ppb and the second draw sample is close to 10ppb or more, the outlet and the building plumbing are contributing lead to the drinking water. LEW Corporation recommends immediately stopping use of these outlets. LEW Corporation then recommends replacing the outlet and associated plumbing up to the wall connection, and installing a lead filter at the wall connection. A filter maintenance plan will need to be implemented, in order to ensure that all filters are in proper working order.

A complete list of recommendations per outlet can be found in Appendix B.

After all mitigation work is complete, follow-up samples should be collected in order to determine the effectiveness of the work.

Appendix A Exceedances

Bernards Township Public Schools Water Sampling Results
Exceedances

Building	DateCollected	AnalysisDate	Sample ID	Sample Description 1st Draws	Concentration (ppb)
Cedar Hill	6/24/2016	6/27/2016	100-5	Kitchen Prep Sink By Refrigerator Sink 1st	24.4
Cedar Hill	6/24/2016	6/27/2016	100-6	Kitchen Prep By Freezer Door Sink 1st Dra	47.2
Cedar Hill	6/24/2016	6/27/2016	100-7	Kitchen Soup Kettle 1st Draw	15.3
Cedar Hill	6/24/2016	6/27/2016	100-12	Room #100 Fountain 1st Draw	21.4
Liberty Corner	6/23/2016	6/27/2016	61-2	Kitchen Middle By Door Sink #2 1st Draw	17.2
Liberty Corner	6/23/2016	6/27/2016	61-12	Room #204 Fountain/Sink 1st Draw	16.2
Liberty Corner	8/3/2016	8/4/2016	61-2	Room #204 Fountain/Sink 2nd Draw	12.7

Appendix B Recommendations

Bernards Township Schools Water Sampling
Recommendations

Building	Location	Remediation Recommendation
Cedar Hill	Kitchen Prep Sink By Refrigerator Sink	Replace outlet up to wall connection.
Cedar Hill	Kitchen Prep By Freezer Door Sink	Replace outlet up to wall connection.
Cedar Hill	Kitchen Soup Kettle	Replace outlet up to wall connection.
Cedar Hill	Room #100 Fountain	Replace outlet up to wall connection.
Liberty Corner	Kitchen Middle By Door Sink #2	Replace outlet up to wall connection.
Liberty Corner	Room #204 Fountain/Sink	Replace outlet up to wall connection.
Liberty Corner	Room #204 Fountain/Sink	Replace outlet up to wall connection. Install filter between wall connection and outlet

Appendix C All Results

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Ridge High School	6/22/2016	6/23/2016	268-1	Kitchen By Green Wall Sink #1	<5.00
Ridge High School	6/22/2016	6/23/2016	268-2	Kitchen By Orange Wall Sink #2	<5.00
Ridge High School	6/22/2016	6/23/2016	268-3	Kitchen By Refridgerator Sink #3	<5.00
Ridge High School	6/22/2016	6/23/2016	268-4	Kitchen #2 Sink #4	<5.00
Ridge High School	6/22/2016	6/23/2016	268-5	Tutorial Center Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-6	Café Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-7	Café Right-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-8	By L-7 Boys Locker Rm Lft-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-9	By L-7 Boys Locker Rm Rgt-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-10	Kitchen Ice Machine	<5.00
Ridge High School	6/22/2016	6/23/2016	268-11	Counseling & Special Services Rm Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-12	Counseling & Special Services Rm Coffee Machine	<5.00
Ridge High School	6/22/2016	6/23/2016	268-13	Main Office Work Rm Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-14	By Main Office Left-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-15	By Main Office Right-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-16	Band Rm #222 Fountain/Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-17	Orchestra Rm #223 Fountain/Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-18	Nurse Office Rm #201 Sink #1	<5.00
Ridge High School	6/22/2016	6/23/2016	268-19	Nurse Office Rm #201 By Mirror Sink #2	<5.00
Ridge High School	6/22/2016	6/23/2016	268-20	By Room #205 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-21	By Room #205 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-22	Teachers Lounge Rm #209 Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-23	PAC By Rm #230 Left-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-24	PAC By Rm #230 Right-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-25	Room #230 Fountain/Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-26	By Green Rm Hallway Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-27	By Rm #701 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-28	By Rm #701 Hallway Right-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-29	By Rm #722 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-30	By Rm #722 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-31	Room #533 Work Rm Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-32	By Rm #525 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-33	By Rm #525 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-34	Room #505 Life Skills Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-35	By Rm #505 Hallway Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-36	Room #513 Sink	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Ridge High School	6/22/2016	6/23/2016	268-37	Media Center Rm #500 C Sink	<5.00
Ridge High School	6/22/2016	6/23/2016	268-38	By Rm #306 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-39	By Rm #306 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-40	By L-4 Girls Locker Rm Left-Side Fountain	5.09
Ridge High School	6/22/2016	6/23/2016	268-41	By L-4 Girls Locker Rm Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-42	By Room #404 Hallway Left-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-43	By Room #404 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-44	By Room #613 Hallway Left-Side Fountain/Bottle Station	<5.00
Ridge High School	6/22/2016	6/23/2016	268-45	By Room #613 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-46	By Room #620 Hallway Left-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-47	By Room #620 Hallway Right-Side Fountain	<5.00
Ridge High School	6/22/2016	6/23/2016	268-48	Gym By Drying Rm Ice Machine	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-1	Café Fountain/Bottle Station	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-2	Faculty Rm #207 Coffee Maker	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-3	Kitchen Left-Side Main Sink #1	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-4	Kitchen Right-Side Main Sink #2	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-5	Kitchen Prep Sink By Refrigerator Sink	24.4
Cedar Hill	6/24/2016	6/27/2016	100-6	Kitchen Prep By Freezer Door Sink	47.2
Cedar Hill	6/24/2016	6/27/2016	100-7	Kitchen Soup Kettle	15.3
Cedar Hill	6/24/2016	6/27/2016	100-8	Nurse Officd Sink	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-9	1st Floor Hallway By Library Fountain	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-10	1st Floor Hallway By Room #100 Fountain/Bottle Station	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-11	Room #104 Fountain/Sink	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-12	Room #100 Fountain	21.4
Cedar Hill	6/24/2016	6/27/2016	100-13	Room #102 Fountain	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-14	1st Floor Hallway By Room #407 Fountain/Bottle Station	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-15	Room #508 Fountain/Sink	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-16	1st Floor Hallway By Rm #504 Left-Side Fountain	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-17	1st Floor Hallway By Rm #504 Rgt-Side Fountain/Bottle Station	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-18	1st Floor Hallway By Rm #505 Rgt-Side Fountain	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-19	1st Floor Hallway By Rm #505 Left-Side Fountain	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-20	Room #506 Fountain/Sink	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-21	Room #507 Fountain/Sink	<5.00
Cedar Hill	6/24/2016	6/27/2016	100-22	Room #509 Fountain/Sink	<5.00
Bernards Township B0	6/24/2016	6/27/2016	101-1	Kitchen Sink	<5.00
Bernards Township B0	6/24/2016	6/27/2016	101-2	Kitchen Cooler	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Mount Prospect	6/23/2016	6/6/30/16	111-1	Main Office Cooler	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-2	1st Floor Hallway By Main Office Fountain	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-3	Room #122 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-4	Room #124 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-5	Room #125 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-6	Room #127 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-7	Room #126 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-8	Room #120 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-9	Room #218 Fountian/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-10	Room #219 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-11	Room #217 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-12	Room #216 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-13	Room #214 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-14	Room #181 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-15	Room #215 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-16	Room #213 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-17	Room #212 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-18	Room #211 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-19	Room #209 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-20	Room #207 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-21	Room #205 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-22	2nd Floor Hallway Fountain	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-23	Room #251 Faculty Rm Cooler	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-24	Room #251 Faculty Rm Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-25	Room #252 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-26	Room #254 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-27	Room #174 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-28	Room #256 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-29	Room #257 Right-Side Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-30	Room #257 Left-Side Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-31	Room #258 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-32	Room #260 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-33	Room #262 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-34	Room #259 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-35	Room #261 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-36	Room #263 Fountain/Sink	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Mount Prospect	6/23/2016	6/6/30/16	111-37	Room #264 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-38	Room #185 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-39	Room #186 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-40	Room #183 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-41	Room #184 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-42	Room #179 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-43	Room #180 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-44	Room #178 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-45	Room #176 Fountain/Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-46	1st Floor Hallway By Café Left-Side Fountain	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-47	1st Floor Hallway By Café Middle Fountain	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-48	1st Floor Hallway By Café Right-Side Fountain	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-49	Kitchen Left-Side Sink #1	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-50	Kitchen Middle Sink #2	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-51	Kitchen Right-Side Sink #3	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-52	Kitchen Soup Kettle Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-53	Nurse Office Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-54	Nurse Office Bathroom Sink	<5.00
Mount Prospect	6/23/2016	6/6/30/16	111-55	Room #182 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-1	2nd Floor Hallway By Room #25 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-2	2nd Floor Hallway By Room #22 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-3	Teachers Lounge Cooler	<5.00
Oak St	6/24/2016	6/28/2016	70-4	Teachers Lounge Coffee Maker	<5.00
Oak St	6/24/2016	6/28/2016	70-5	1st Floor Hallway By Room #39 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-6	1st Floor Hallway By Room #35 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-7	Room #1 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-8	Room #2 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-9	Room #3 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-10	1st Floor Hallway By Rest Rm Right-Side Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-11	1st Floor Hallway By Rest Rm Left-Side Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-12	1st Floor Hallway By Room #5 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-13	1st Floor Hallway By Room #9 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-14	1st Floor Hallway By Room #13 Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-15	Room #15 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-16	Room #17 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-17	1st Floor Hallway By Room #19 Right-Side Fountain	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Oak St	6/24/2016	6/28/2016	70-18	1st Floor Hallway By Room #19 Left-Side Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-19	Room #18 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-20	Room #14 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-21	Room #12 Fountain/Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-22	1st Floor Hallway By Gym Mens Rm Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-23	1st Floor Hallway By Gym Girls Rm Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-24	Café Left-Side Fountain	<5.00
Oak St	6/24/2016	6/28/2016	70-25	Café Right-Side Fountain/Bottle Station	<5.00
Oak St	6/24/2016	6/28/2016	70-26	Kitchen By Oven Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-27	Kitchen By Storage Rm Right-Side Sink	8.09
Oak St	6/24/2016	6/28/2016	70-28	Kitchen By Storage Rm Left-Side Sink	<5.00
Oak St	6/24/2016	6/28/2016	70-29	Nurse Office Sink	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-1	Nurse Office Sink	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-2	Kitchen By Orange Wall Left-Side Sink#1	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-3	Kitchen By Orange Wall Middle Sink #2	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-4	Kitchen By Orange Wall Right-Side Sink #3	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-5	Kitchen In Back Of Refrigerator Sink #4	7.45
William Annin Middle \$	6/24/2016	6/29/2016	70-6	Kitchen Prep Sink By Orange Wall Sink #5	7.85
William Annin Middle \$	6/24/2016	6/29/2016	70-7	Kitchen By Ice Machine Sink #6	8.16
William Annin Middle \$	6/24/2016	6/29/2016	70-8	Café Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-9	1st Floor Hallway By Room #212 Left-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-10	1st Floor Hallway By Room #212 Middle Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-11	1st Floor Hallway By Room #212 Right-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-12	Room #219 Sink #1	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-13	Room #219 Sink #2	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-14	Room #219 Sink #3	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-15	Room #219 Sink #4	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-16	Room #219 Sink #5	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-17	Room #219 Sink #6	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-18	1st Floor Hallway By Room 117 Left-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-19	1st Floor Hallway By Room #117 Right-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-20	1st Floor Hallway By Gym Rm #108 Left-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-21	1st Floor Hallway By Gym Rm #108 Right-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-22	1st Floor Hallway By Rm #211 Left-Side Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-23	1st Floor Hallway By Rm #211 Middle Fountain	<5.00
William Annin Middle \$	6/24/2016	6/29/2016	70-24	1st Floor Hallway By Rm #211 Right-Side Fountain	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
William Annin Middle	6/24/2016	6/29/2016	70-25	Boys Locker Room #204 Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-26	Girls Locker Room #206 Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-27	1st Floor Hallway By Rm #306 Left-Side Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-28	1st Floor Hallway By Rm #306 Middle Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-29	1st Floor Hallway By Rm #306 Right-Side Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-30	1st Floor Hallway By Rm #317 Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-31	1st Floor Hallway By Rm #316A Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-32	1st Floor Hallway By Elevator Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-33	2nd Floor Hallway By Rm #405 Left-Side Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-34	2nd Floor Hallway By Rm #405 Middle Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-35	2nd Floor Hallway By Rm #405 Right-Side Fountain	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-36	Room #407 Cooler	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-37	Media Center Sink	<5.00
William Annin Middle	6/24/2016	6/29/2016	70-38	Main Office Cooler	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-1	Kitchen Left-Side By Door Sink #1	11.8
Liberty Corner	6/23/2016	6/27/2016	61-2	Kitchen Middle By Door Sink #2	17.2
Liberty Corner	6/23/2016	6/27/2016	61-3	Kitchen Right-Side By Door Sink #3	5.87
Liberty Corner	6/23/2016	6/27/2016	61-4	Kitchen Prep Sink #4	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-5	Kitchen Soup Kettle	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-6	Room #1043 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-7	Room #100 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-8	Faculty Room Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-9	Room #102 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-10	2nd Floor Hallway By Room #202 Fountain	7.21
Liberty Corner	6/23/2016	6/27/2016	61-11	Room #205 Fountain/Sink	5.66
Liberty Corner	6/23/2016	6/27/2016	61-12	Room #204 Fountain/Sink	16.2
Liberty Corner	6/23/2016	6/27/2016	61-13	Room #201 Fountain/Sink	5.6
Liberty Corner	6/23/2016	6/27/2016	61-14	Room #208 Fountain/Sink	5.65
Liberty Corner	6/23/2016	6/27/2016	61-15	Room #209 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-16	Room #210 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-17	Room #212 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-18	2nd Floor Hallway By Rm #213 Fountain	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-19	2nd Floor Hallway By Rm #216 Fountain	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-20	Room #218 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-21	Room #220 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-22	Room #120 Fountain/Sink	<5.00

Berarnds Township Public School Water Sampling Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Liberty Corner	6/23/2016	6/27/2016	61-23	Room #118 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-24	1st Floor Hallway By Nurse Office Fountain	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-25	Nurse Office Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-26	Room #114 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-27	Lower Level Hallway By Rm #18 Fountain	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-28	Room #16 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-29	Lower Level Hallway By Rm 14 Fountain	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-30	Room #14 Fountain/Sink	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-31	Lower Level Hallway By Gym Left-Side Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-32	Lower Level Hallway By Gym Right-Side Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-33	1st Floor Hallway By Rm #111 Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-34	Room #110 Fountain/Sink 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-35	Room #108 Fountain/Sink 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-36	Room #107 Fountain/Sink 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-37	Room #106 Fountain/Sink 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-38	Room #105 Fountain/Sink 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-39	Room #104 Fountain/Sink 1st Draw	11.7
Liberty Corner	6/23/2016	6/27/2016	61-40	1st Floor Hallway By Café Left-Side Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-41	1st Floor Hallway By Café Right-Side Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-42	Café Fountain 1st Draw	<5.00
Liberty Corner	6/23/2016	6/27/2016	61-43	2nd Floor Hallway By Storage Rm "C" Fountain 1st Draw	<5.00
Cedar Hill	8/3/2016	8/4/2016	100-1	Room #100 Fountain 2nd Draw	<5.00
Cedar Hill	8/3/2016	8/4/2016	100-2	Kitchen Prep Sink By Refrigerator 2nd Draw	<5.00
Cedar Hill	8/3/2016	8/4/2016	100-3	Kitchen Prep Sink By Freezer Door 2nd Draw	<5.00
Cedar Hill	8/3/2016	8/4/2016	100-4	Kitchen Soup Kettle	<5.00
Liberty Corner	8/3/2016	8/4/2016	61-1	Kitchen Middle By Door Sink #2 2nd Draw	<5.00
Liberty Corner	8/3/2016	8/4/2016	61-2	Room #204 Fountain/Sink 2nd Draw	12.7